



Oak Park

DEPARTMENT OF BUILDING & PROPERTY STANDARDS
E-mail: Building@oak-park.us Fax: 708-358-5441

ADDRESS: 624 S Hummer	DATE: 2/4/05
PROJECT: PRELIMINARY REVIEW	PAGE OF:
	REVIEWER: JAKES

Homeowner picked up plans for revisions 2/25/05

Documents Submitted:

- 1) Plat of Survey
- 2) Application - Elec/HVAC/Plumb
- 3) Affidavit
- 4) 2 Sets of Plans (4 pages per set)

Comments:

Sheet 1:

1. Provide structural analysis of bearing capacity of supporting system and new WMA assembly.
2. Indicate transfer of loading conditions LUL over main beam?

Sheet 2:

Provide detail of railing/stair.

NEW column -> provide elevation/plan view detail